

Timber Lakes Water Special Service District

175 North Main-STE B4
PO BOX 579
Heber City, Utah 84032
435-654-0125
435-654-4925

2014 Annual Drinking Water Quality \ Report Timber Lakes Water SSD

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources are springs; they are Lone Pine 1 and 2, 3,4,5,6, Cove East and West, and Look Out Mountain. Lone pine 3, 4, 5, and 6 were turned into the system in 2010.

Timber Lakes Water SSD has a Drinking Water Source Protection Plan that is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. It has been determined that we have a low susceptible level to potential sources of contamination, such as septic tanks, roads, homes etc. If you have any questions regarding source protection, contact our office to review our source protection plan. Our sources are in remote locations, and there are no known potential contamination sources in the protection zones, so we consider our source to have a low susceptibility to potential contamination events.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

I'm pleased to report that our drinking water meets federal and state requirements.

If you have any questions about this report please contact Jody Defa at 435-654-0125 or Eric Franson or Vince Hogge with Franson Engineering at 801-756-0309. We want our valued

customer to be informed about their water utility. If you want to learn more, our monthly meetings are held on the third Tuesday of each month at 6:00 P.M. at the Wasatch County building at 25 North Main in Heber City, Utah.

Timber Lakes Water routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2014. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in

drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem out-dated.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	0	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2014	Naturally present in the environment
Fecal Coliform & E. Coli	N	0	N/A	0	0.5 in at least 95% of the samples, never to exceed 5.0	2014	Naturally present in the environment
Turbidity for Ground Water	N	0-0	NTU	N/A	5	2011	Soil runoff
Inorganic Contaminants							
Arsenic	N	.5-.5	ppb	0	10	2011	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	N	.043-.101	ppm	2000	2000	2011	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. .253 b. 0	ppt	1300000	AL=1300000	2012	Corrosion of household plumbing systems; erosion of natural deposits
Lead a. 90% results b. # of sites that exceed the AL	N	a. 3 b. 0	ppt	0	AL=15000	2012	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	500-600	ppb	10000	10,000	2014	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
TDS (Total Dissolved solids)	N	122-154		2000	2000	2011	Erosion of natural deposits
Radioactive Contaminants							
Alpha emitters	N	1-2	pCi/l	0	15	2011	Erosion of natural deposits
Radium 228	N	0-1	pCi/l	0	5	2011	Erosion of natural deposits
Disinfection By-products							

TTHM [Total trihalomethanes]	N	6	ppb	No goal for total	80	2014	By-product of drinking water disinfection
Haloacetic Acids	N	6	ppb	No goal for total	60	2014	By-product of drinking water disinfection
Chlorine	N	.5	ppm	4	4	2014	Water additive used to control microbes.

In addition to the sampling outlined above, we have also sampled for (31 Synthetic Organic Contaminants, Radiological Contaminants and 1 Unregulated Contaminant including Pesticides). These additional chemicals were not detected.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Timber Lakes Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Timber Lakes Water SSD
P.O. Box 579
Heber City, UT 84032

April 20, 2015

Colt Smith
CCR Compliance
Division of Drinking Water
P.O. Box 144830
Salt Lake City, Utah 84114-4830

Dear Mr. Smith:

Subject: Consumer Confidence Report for Timber Lakes Water SSD # 26057

Enclosed is a copy of the Timber Lakes Water SSD Consumer Confidence Report. It contains the water quality information for our water system for the calendar year 2014 or the most recent sample data.

We have delivered this report to our customers by mailing it directly to each customer.

If you have any questions, please contact me at 801-420-1186.

Sincerely,

Jody Defa
Timber Lakes Water SSD